

AVE Wels – Waste Incineration System

LOCATION: Wels, Austria

SYSTEM/TECHNOLOGY: PS416 with Sucusoft S40 communication with PLS via Profibus-DP

SERVICES: Commissioning, Project management, Documentation, Basic-engineering and pre-engineering, Detail engineering, Installation supervision

INDUSTRY BRANCH/TYPE OF PLANT: Power Generation, Waste incineration systems

CLIENT: AVE Austria

PROJECT SIZE: EUR 200,000

TASK

- Combustion power controls (FLR) with "INP FUZZY CONTROL" for biomass and waste
- Infeed grate, boiler 1
- INSPECT video camera integration
- Training of the plant personnel
- Service and support
- Increase in the waste throughput by 10%
- Significant increase in availability
- Compliance with Federal Pollution Control Act (BImSchG) emissions values
- Low operating times of the backup burners
- Low steam fluctuations with regard to the set point specification $\pm 3.5\%$
- Reduction in ignition losses $< 3\%$
- Stabilization of the temperature ratio with regard to material adhesions and encrustation

DESCRIPTION OF DELIVERIES AND ACTIVITIES OF "INP FUZZY CONTROL" COMBUSTION POWER CONTROLS

- Process engineering concept on the basis of current process data and auditing of the plant operators
- Process optimization by modelling and simulation
- Improvement in highly-sensitive process sequences
- Specifications for modified operating concepts
- Use of fuel for energy
- Increase in performance
- Open and transparent control concept on the basis of multi-variable characteristic map control
- Stabilization of the steam output and oxygen content in the flue gas

POINTS OF CONTACT



Tobias Hoffmann

Geschäftsführer

INP Austria GmbH

Gaisbacher Str. 6

4210 Gallneukirchen

Österreich

Tel. +43 7235 22188-11

Fax +43 7235 22188-99

tobias.hoffmann@inp-e.com

www.inp-e.com

INP Reference

- Optimization of thermal combustion processes
- Saving operating substances (reduction agent)
- Use and reduction in emission limit values

TARGETS/KEY FIGURES OF THE "INP FUZZY CONTROL" COMBUSTION POWER CONTROLS

- Significant reduction in fluctuation range in all load cases
- Largely constant flue gas volume
- Significant reduction in CO peaks
- Smoothly running combustion process
- Reduction in strain on the involved and down-circuit units
- Reduction in the message sequence procedure
- Saving of service products in the de-dusting system and flue gas purification
- Increase in gross heat output and throughput rate
- Stabilization of the firing chamber temperature and residual O₂ concentration in the flue gas
- Reduction in emissions of carbon monoxide compared to the current operating method
- Homogenization of steam quantity production (see created analysis of 7 %)